

Flexible Coupling for Shouldered Steel Pipe

Style SC77



16.10



1.0 PRODUCT DESCRIPTION

Available Sizes

- 2 – 8"/DN50 – DN200

NOTE

- For sizes 10 – 12"/DN250 – DN300 refer to [submittal 16.21](#): Victaulic Style SC85 coupling.

Maximum Working Pressure

- Up to 580 psi/4000 kPa/40 Bar.
- Pressure rating dependent upon size, weight and material of pipe.

Application

- Utilizes Installation-Ready™ technology.
- This product joins shouldered steel pipe, shouldered fittings and/or shouldered valves.
- Provides a flexible pipe joint which allows for some expansion, contraction and deflection.
- Operating temperature dependent upon gasket and/or seal selection (see section 3.0).

Pipe or Tube Materials

- Shouldered steel

Codes and Requirements

- Support and hanging requirements for flexible systems are listed in the I-100 Victaulic Field Installation Handbook (see section 7.0).

2.0 CERTIFICATION/LISTINGS

Product manufactured by Victaulic and/or certified suppliers in accordance with ISO-9001.

ALWAYS REFER TO ANY NOTIFICATIONS AT THE END OF THIS DOCUMENT REGARDING PRODUCT INSTALLATION, MAINTENANCE OR SUPPORT.



3.0 SPECIFICATIONS – MATERIAL

Housing: Ductile iron conforming to ASTM A536, Grade 65-45-12.

Housing Coating: (specify choice)

- ☐ Standard: Hot dipped galvanized.
- ☐ Optional: Orange enamel.
- ☐ Optional: Others, contact Victaulic with your requirements.

Gasket:¹

☐ **Grade “T” Nitrile**

Nitrile (Orange stripe color code). Temperature range -20°F to +180°F/-29°C to +82°C. May be specified for petroleum products, air with oil vapors, vegetable and mineral oils within the specified temperature range. Not compatible for hot water services over +150°F/+66°C or for hot dry air over +140°F/+60°C.

¹ Services listed are General Service Guidelines only. It should be noted that there are services for which these gaskets are not compatible. Reference should always be made to the latest [Victaulic Seal Selection Guide](#) for specific gasket service guidelines and for a listing of services which are not compatible.

Bolts/Nuts: (specify choice^{2,3})

• **Australia Only -**

- ☐ Standard: Carbon steel oval neck track bolts meeting the mechanical property requirements of ASTM A449. Carbon steel heavy hex nuts meeting the mechanical property requirements of ASTM A563 Grade B. Track bolts and heavy hex nuts are hot-dipped galvanized.
- ☐ Optional:² Zinc-electroplated per ASTM B633 ZN/FE5, finish Type III (clear chromate).

² Optional bolts/nuts are available in imperial size only.


• **South Africa Only –**

- ☐ Standard: Carbon steel oval neck track bolts meeting the mechanical property requirements of ISO 898-1 Class 9.8 for sizes M10-M16, and Class 8.8 for sizes M20 and larger. Carbon steel heavy hex nuts meeting the mechanical property requirements of ASTM A563M Class 9. Track bolts and heavy hex nuts are hot-dipped galvanized.
- ☐ Optional:³ Zinc-electroplated per ASTM B633 ZN/FE5, finish Type II (yellow chromate).


³ Optional bolts/nuts are available in metric size only.

4.0 DIMENSIONS

Style SC77



Style SC77 Pre-Assembled
(Installation-Ready Condition)




Style SC77 Joint Assembled

Size			Allowable Pipe End Separation		Bolt/Nut		Dimensions					Weight
Nominal inches mm	Actual Pipe Outside Diameter inches mm	Actual Shoulder Outside Diameter inches mm	Minimum ⁴ inches mm	Maximum ⁵ inches mm	Qty.	Size inches mm	Pre-assembled (Installation-Ready™ condition)		Joint Assembled			Approximate (Each) lb kg
							X inches mm	Y inches mm	X inches mm	Y inches mm	Z inches mm	
2 DN50	2.375 60.3	2.618 66.5	0.13 3.3	0.30 7.6	2	¾ x 2 ½ M10 x 64	4.00 102	6.00 152	3.63 90	6.13 156	2.13 52	2.2 1.0
3 DN80	3.500 88.9	3.819 97.0	0.13 3.3	0.30 7.6	2	½ x 3 ¼ M12 x 83	6.25 159	7.75 197	4.75 119	7.88 198	2.13 52	3.3 1.5
4 DN100	4.500 114.3	4.803 122.0	0.13 3.3	0.30 7.6	2	½ x 3 ¼ M12 x 83	6.25 159	8.75 222	5.75 144	8.75 221	2.25 57	4.2 1.9
	6.500 165.1	6.870 174.5	0.13 3.3	0.30 7.6	2	⅝ x 4 M16 x 101	8.50 216	11.83 300	7.88 200	11.65 296	2.25 57	7.9 3.6
8 DN200	8.625 219.1	9.134 232.0	0.19 4.8	0.46 11.7	2	⅝ x 4 M16 x 101	11.00 279	14.25 362	10.25 260	14.13 359	2.88 73	12.3 5.6

⁴ The minimum pipe end separation as required by the gasket center leg. See Illustrations below.

⁵ Maximum pipe end separation to be used for determining overall piping system growth. For design and installation purposes, the linear movement and angular deflection values shown in the table below should be used. See illustrations below.



Minimum Pipe Separation

Maximum Pipe Separation

Exaggerated for clarity

4.1 DIMENSIONS

Design and Installation

The amount of linear movement and angular deflection to be used for design and installation consideration for each coupling is shown in the table below.

Size			Expansion Allowance inches mm	Deflection from Centerline Per Coupling Degrees	Deflection from Centerline Pipe inches per ft. mm per m
Nominal inches mm	Actual Pipe Outside Diameter inches mm	Actual Shoulder Outside Diameter inches mm			
2 DN50	2.375 60.3	2.618 66.5	0.09 2.3	2°15'	0.45 38
3 DN80	3.500 88.9	3.819 97.0	0.09 2.3	1°85'	0.38 32
4 DN100	4.500 114.3	4.803 122.0	0.13 3.3	1°75'	0.37 31
	6.500 165.1	6.870 174.5	0.13 3.3	1°15'	0.24 20
8 DN200	8.625 219.1	9.134 232.0	0.20 5.1	0°85'	0.17 15

5.0 PERFORMANCE

Style SC77

Size			Wall Thickness	Maximum Working Pressure ^{6,7}	Maximum End Load ⁶
Nominal	Actual Pipe Outside Diameter	Actual Shoulder Outside Diameter			
inches mm	inches mm	inches mm	inches mm	psi Bar	lb N
2 DN50	2.375 60.3	2.618 66.5	0.154 3.91	580 40	3125 13900
3 DN80	3.500 88.9	3.819 97.0	0.216 5.49	580 40	6650 29580
4 DN100	4.500 114.3	4.803 122.0	0.237 6.02	580 40	10510 46750
	6.500 165.1	6.870 174.5	0.280 7.11	580 40	21500 95630
8 DN200	8.625 219.1	9.134 232.0	0.320 8.10	580 40	38000 169000

⁶ The above ratings represent the maximum allowable working pressure and permissible end load of the coupling on Sch 40 carbon steel pipe. Contact Victaulic for details.

⁷ It is the responsibility of the engineering specifier to verify the pressure rating of all other system components.

NOTE

- WARNING: Depressurize and drain the piping system before attempting to install, remove or adjust any Victaulic piping products.
- WARNING: FOR ONE TIME FIELD TEST ONLY, the Maximum Joint Working Pressure may be increased to 1½ times the figures shown.

6.0 NOTIFICATIONS

! WARNING




- Read and understand all instructions before attempting to install any Victaulic products.
- Always verify that the piping system has been completely depressurized and drained immediately prior to installation, removal, adjustment, or maintenance of any Victaulic products.
- Confirm that any equipment, branch lines, or sections of piping that may have been isolated for/during testing or due to valve closures/positioning are identified, depressurized, and drained immediately prior to installation, removal, adjustment, or maintenance of any Victaulic products.
- Wear safety glasses, hardhat, foot protection, and hearing protection.
- Style SC77 Couplings shall be installed only with shouldered-end mating components.
- When assembling Style SC77 Couplings onto Victaulic® No. SC60 End Caps, take additional time to inspect and verify that the end cap is seated fully against the center leg of the gasket.
- Always read and follow the [I-ENDCAP](#), Victaulic® End Cap Installation Safety Instructions, which can be downloaded at Victaulic.com.
- DO NOT use non-Victaulic® fittings with Style SC77 Couplings.

Failure to follow these instructions could result in death or serious personal injury and property damage.

7.0 REFERENCE MATERIALS

Shouldered End Preparation



Nominal inches Actual mm	P Diameter inches mm	S Diameter inches mm	L inches mm	Stand off inches mm
2 DN50	2.375 60.3	2.618±0.031 66.5±0.8	0.630±0.031 16±0.8	0.20 5.0
3 DN80	3.500 88.9	3.819±0.031 97.0±0.8	0.630±0.031 16±0.8	0.20 5.0
4 DN100	4.500 114.3	4.803±0.031 122.0±0.8	0.689±0.031 17.5±0.8	0.25 6.5
	6.500 165.1	6.870±0.031 174.5±0.8	0.689±0.031 17.5±0.8	0.25 6.5
8 DN200	8.625 219.1	9.134±0.031 232.0±0.8	0.807±0.031 20.5±0.8	0.25 6.5

NOTE

- Welded-on shoulder rings must be a near tight fit to the pipe. Care is required when fitting shoulder rings to ensure that ring distortion does not occur. It is equally important that the distance between the edge of the steel shoulder ring and the end of the pipe be accurately consistent with the figures published above. If the pipe "stand off" is exceeded distortion will occur.
- For shouldered pipe end preparation guidelines for sizes 10 – 12"/DN250 – DN300, refer to [submittal 16.21](#): Victaulic Style SC85 Coupling

[I-SC77: Victaulic Style SC77 Installation Instructions](#)

[05.01: Seal Selection Guide](#)

[07.06: Victaulic Shouldered Fittings Submittal](#)

[08.31: Victaulic Shouldered Butterfly Valve Submittal](#)

[08.44: Victaulic Shouldered Gate Valve Submittal](#)

[16.21: Victaulic Style SC85 Coupling Submittal](#)

[I-100: Field Installation Handbook](#)

User Responsibility for Product Selection and Suitability

Each user bears final responsibility for determining the suitability of Victaulic products for their end-use application, in accordance with industry standards, project specifications, and Victaulic's published performance, maintenance, and safety data, as well as all warnings and installation instructions. Nothing in this or any other document, nor any verbal recommendation, advice, or opinion from any Victaulic employee, shall be deemed to alter, vary, supersede, or waive any provision of Victaulic Company's standard conditions of sale, warranty, installation instructions, or this disclaimer.

Installation

Always refer to and follow the [Victaulic Installation Handbook](#) or installation instructions for the product you are installing. Handbooks are included with each shipment of Victaulic products, providing complete installation and assembly data, and are available in PDF format on our website at [victaulic.com](#).

Warranty

Refer to the Warranty section of the current Price List or contact Victaulic for details.

Intellectual Property Rights

No statement concerning the use of any material, product, service, or design is intended, or should be construed, to grant any license under any patent or other intellectual property right of Victaulic or any of its affiliates, or as a recommendation for the use of such material, product, service, or design in the infringement of any patent or other intellectual property right. The terms "Patented" or "Patent Pending" refer to design or utility patents or patent applications for articles and/or methods of use in the United States and/or other countries. Victaulic and all other Victaulic marks are the trademarks or registered trademarks of Victaulic Company, and/or its affiliated entities, in the U.S. and/or other countries.

Note

All products bearing a Victaulic trademark are manufactured by Victaulic or to Victaulic specifications. All products are to be installed only in accordance with the applicable Victaulic installation instructions. Victaulic reserves the right to change product specifications, designs and standard equipment without notice and without incurring obligations.