

Victaulic® FireLock™ Series FL-QR/ST/ESFR
Storage, Fast Response
ESFR Pendent Sprinklers K22.4 (32.0)



1.0 PRODUCT DESCRIPTION

ESFR PENDENT APPROVALS/LISTINGS		
SIN	V4806	V4808
SPRINKLER TYPE	NFPA-ESFR Storage	NFPA- ESFR/FM-Quick Response Storage
SPRINKLER RESPONSE	QR	QR
ORIENTATION	Pendent	Pendent
K-FACTOR ¹	22.4 Imp./32.0 S.I.	22.4 Imp./32.0 S.I.
CONNECTION	1" NPT/25 mm BSPT/IGS™ Grooved	1" NPT/25 mm BSPT/IGS™ Grooved
MAX. WORKING PRESSURE	175 psi (1200 kPa)	175 psi (1200 kPa)

AVAILABLE WRENCHES		
SPRINKLER	V46 Open End	3/16 Hex-Bit (V9)
V4808	■	■
V4806	■	■

Factory Hydrostatic Test: 100% @ 500 psi/3447 kPa/34 bar

Min. Operating Pressure: UL/FM: 7 psi/48 kPa/.5 bar

¹ For K-Factor when pressure is measured in bar, multiply S.I. units by 10.0.

ALWAYS REFER TO ANY NOTIFICATIONS AT THE END OF THIS DOCUMENT REGARDING PRODUCT INSTALLATION, MAINTENANCE OR SUPPORT.



2.0 CERTIFICATIONS/LISTINGS



ESFR PENDENT APPROVALS/LISTINGS			
	NFPA (cULus)	FM	NFPA (FM)
SIN	V4806	V4808	
Nominal K Factor Imperial	22.4	22.4	22.4
Nominal K Factor S.I. ²	32.0	32.0	32.0
Sprinkler Type	ESFR	Quick Response Storage	Quick Response Storage
System Type	Wet	Wet	Wet
Approved Temperature Rating			
Temperature Rating	165°F/74°C 212°F/100°C	165°F/74°C 212°F/100°C	165°F/74°C 212°F/100°C
Maximum Area of Coverage	100ft ² /9.1m ²	100ft ² /9.1m ²	100ft ² /9.1m ²
Minimum Area of Coverage	64ft ² /6m ²	64ft ² /6m ²	64ft ² /6m ²
Maximum Slope Ceiling	NFPA 13	Datasheet 2-0 and 8-9	NFPA 13
Maximum Spacing	12ft/3.6m for up to 30ft/9.1m ceiling 10ft/3m for over 30ft/9.1m ceiling	12ft/3.6m for up to 30ft/9.1m ceiling 10ft/3m for over 30ft/9.1m ceiling	12ft/3.6m for up to 30ft/9.1m ceiling 10ft/3m for over 30ft/9.1m ceiling
Minimum Spacing	8ft/2.4m	8ft/2.4m	8ft/2.4m
Deflector to Ceiling Distance ³	NFPA 13	Datasheet 2-0 and 8-9	NFPA 13
Minimum Deflector to Top of Storage	3 ft/0.9m	3 ft/0.9m	3 ft/0.9m
Minimum Deflector Distance from Walls	4"/100 mm	4"/100 mm	4"/100 mm
Sprinkler System Design	12 A.S @ Approved Pressures per NFPA 13 when more are required	12 A.S @ Approved Pressures per Datasheet 2-0 and 8-9 when more are required	12 A.S @ Approved Pressures per NFPA 13 when more are required
Storage Type	Applicable Standards		
Open Frame (that is, no solid shelves) Single, Double, Multiple-Row, or Portable Rack Storage of Class I-IV and Group A or B Plastics	NFPA 13	Datasheet 8-9	NFPA 13
Solid Pile or Palletized Storage of Class I-IV and Group A or B Plastics	NFPA 13	Datasheet 8-9	NFPA 13
Idle Pallet Storage	NFPA 13	Datasheet 8-24	NFPA 13
Rubber Tire Storage	NFPA 13	Datasheet 8-3	NFPA 13
Rolled Paper Storage (Refer to the standard.)	NFPA 13	Datasheet 8-21	NFPA 13
Flammable Liquid Storage (Refer to the standard.)	NFPA 30	Datasheet 7-29	NFPA 30
Aerosol Storage (Refer to the standard.)	NFPA 30B	Datasheet 7-31	NFPA 30

² For K-Factor when pressure is measured in bar, multiply S.I. units by 10.

³ Distance is taken from the center of the thermal element for FM.

NOTES

- Reference the specific agency website listings for the most up-to-date certification information.

¹ Applies to V4808 only

3.0 SPECIFICATIONS – MATERIAL

Deflector: Brass

Load Screw: Stainless Steel

Pip Cap: Brass

Spring Seal: PTFE Coated Beryllium Nickel Alloy

Frame: Cast Brass

Link: Nickel

Lever: Monel or Stainless Steel

Strut: Monel or Stainless Steel

Coupling: Refer to Victaulic [Publication 10.65](#)



Installation Wrench: Ductile Iron

Sprinkler Frame Finishes: Plain Brass

NOTE

- For cabinets and other accessories refer to separate sheet.

4.0 DIMENSIONS



5.0 PERFORMANCE

Sprinkler systems are to be designed and installed per NFPA, FM Datasheets, and any local standards.

6.0 NOTIFICATIONS

! WARNING



- Read and understand all instructions before attempting to install any Victaulic products.
- Always verify that the piping system has been completely depressurized and drained immediately prior to installation, removal, adjustment, or maintenance of any Victaulic products.
- Wear safety glasses, hardhat, and foot protection.

Failure to follow these instructions could result in death or serious personal injury and property damage.

- These products shall be used only in fire protection systems that are designed and installed in accordance with current, applicable National Fire Protection Association (NFPA) standards, or equivalent standards, and in accordance with applicable building and fire codes. These standards and codes contain important information regarding protection of systems from freezing temperatures, corrosion, mechanical damage, etc.
- The installer shall understand the use of this product and why it was specified for the particular application.
- The installer shall understand common industry safety standards and potential consequences of improper product installation.
- It is the system designer's responsibility to verify suitability of materials for use with the intended fluid media within the piping system and external environment.
- The material specifier shall evaluate the effect of chemical composition, pH level, operating temperature, chloride level, oxygen level, and flow rate on materials to confirm system life will be acceptable for the intended service.

Failure to follow installation requirements and local and national codes and standards could compromise system integrity or cause system failure, resulting in death or serious personal injury and property damage.

7.0 REFERENCE MATERIALS

[10.65: Victaulic® FireLock™ IGS™ Installation-Ready™ Style V9 Sprinkler Coupling](#)

[1-40: Victaulic® FireLock™ Automatic Sprinklers Installation and Maintenance Instructions](#)

[I-V9: Style V9 Victaulic® FireLock™ IGS™ Installation-Ready™ Sprinkler Coupling Installation Instructions](#)

User Responsibility for Product Selection and Suitability

Each user bears final responsibility for determining the suitability of Victaulic products for their end-use application, in accordance with industry standards, project specifications, and Victaulic's published performance, maintenance, and safety data, as well as all warnings and installation instructions. Nothing in this or any other document, nor any verbal recommendation, advice, or opinion from any Victaulic employee, shall be deemed to alter, vary, supersede, or waive any provision of Victaulic Company's standard conditions of sale, warranty, installation instructions, or this disclaimer.

Installation

Always refer to and follow the [Victaulic Installation Handbook](#) or installation instructions for the product you are installing. Handbooks are included with each shipment of Victaulic products, providing complete installation and assembly data, and are available in PDF format on our website at victaulic.com.

Warranty

Refer to the Warranty section of the current Price List or contact Victaulic for details.

Intellectual Property Rights

No statement concerning the use of any material, product, service, or design is intended, or should be construed, to grant any license under any patent or other intellectual property right of Victaulic or any of its affiliates, or as a recommendation for the use of such material, product, service, or design in the infringement of any patent or other intellectual property right. The terms "Patented" or "Patent Pending" refer to design or utility patents or patent applications for articles and/or methods of use in the United States and/or other countries. Victaulic and all other Victaulic marks are the trademarks or registered trademarks of Victaulic Company, and/or its affiliated entities, in the U.S. and/or other countries.

Note

All products bearing a Victaulic trademark are manufactured by Victaulic or to Victaulic specifications. All products are to be installed only in accordance with the applicable Victaulic installation instructions. Victaulic reserves the right to change product specifications, designs and standard equipment without notice and without incurring obligations.